

From: Jeff Goode
Sent: Tuesday, June 26, 2018 10:24 AM
To: Jeff Goode
Subject: FW: Cheel Arena - Unanswered RFI's (Structural Steel)

From: Mark Bayer [<mailto:Bayer@silman.com>]
Sent: Tuesday, June 26, 2018 9:54 AM
To: Jeff Goode <jeff.goode@hok.com>; Geoffrey Smith <Smith@silman.com>
Subject: RE: Cheel Arena - Unanswered RFI's (Structural Steel)

Typical roof deck is to be 1 ½" 18 gage.

-Mark

From: Jeff Goode <jeff.goode@hok.com>
Sent: Tuesday, June 26, 2018 10:45 AM
To: Mark Bayer <Bayer@silman.com>; Geoffrey Smith <smith@silman.com>
Subject: FW: Cheel Arena - Unanswered RFI's (Structural Steel)

Mark/Geoff,

Can you clarify what type of decking "R1" is?

Reference drawings S115A and S115B: There is a callout for all metal roof deck "R1". After looking through the drawings and specifications, we don't see where type "R1" metal deck has been specified. Please provide what type of metal deck this job requires as it relates to "R1".

Thanks

Jeff Goode
HOK
jeff.goode@hok.com
t +1 816 472 2097